

WATER ANALYSIS REPORT
MDEQ# 9990

Date Reported: 9/14/2022

Site Information

Jonathon Bryant
76735 Scenic Drive
Montague, MI 49437

Parcel #: 64-016-021-300-01

Township: Claybanks

County: Oceana

Source: Other (Agriculture)

WSSN #/Source ID/Well #:

Test Purpose: Construction/New Well

Report Information

Jonathon Bryant
1869 Vanburen
Hudsonville, MI 49426
jbryant@undcom.com

Collection Information

Sample Point: Outside Tap

Date/Time Collected: 9/13/2022 11:00 AM

Sample Collected By: Jonathon Bryant

Sample Matrix: Drinking Water

Date/Time Received: 9/13/2022 1:20 PM

Results

Sample ID #	Analysis	Result	Date/Time Analyzed	Standard Method
27050	Total Coliform	ABSENT	9/13/2022 5:00 PM	9223 B*
27050	E.Coli	ABSENT	9/13/2022 5:00 PM	9223 B*
27051	Nitrate	< 1 mg/L	9/13/2022 5:00 PM	10206*

Maximum Contaminant Levels (MCL): Coliform Nitrate
Absent **10 mg/L**

Comments